

VOC Content Test Certificate

Friday May 30th, 2008

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex CA 20 P multipurpose construction adhesive and sealant

Date Tested: May 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

| | |
|--|---------------------------|
| Specification | |
| Green Building Council of Australia | Ardex CA 20 P |
| Green Star Office Design V2 IEQ -13 | |
| Green Star Office Interiors V1.1 IEQ-11 | |
| Multipurpose Construction Adhesive 70 grams per Litre | 20 grams per Litre |
| Specification | |
| Green Building Council of Australia | Ardex CA 20 P |
| Green Star Office Design V3 IEQ -13 | |
| Multipurpose Construction Adhesive 70 gr ams per Litre | 20 grams per Litre |



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0805-73