

VOC Content Test Certificate

Wednesday 5th April 2023

Supplier: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills, NSW 2147, Australia)

Sample Description: Ardex FG8

Date Tested: March 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Ardex FG8
General Purpose Adhesives and Sealants Limit: 50 grams per litre	1 gram per litre as VOC content per material
Meets GBCA VOC Content Requirement	Yes



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Dr. Tuan Duong
 PhD, BE (Chem. Eng.)
 Senior Consultant



Travis Hale
 BSc (Biotechnology)
 Senior Consultant

Issue date: 23/04/2023

Expiry date: 23/04/2028

P23020085