

# VOC Content Test Certificate

Friday, 12<sup>th</sup> January 2018

Supplier: Ardex Australia Pty Ltd (7/20 Powers Road, Seven Hills, NSW 2147).

Sample Description: Ardex AF 180 MS, One Component Heavy Duty Adhesive

Date Tested: January 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p align="center"><b>Specification</b></p> <p align="center"><b>Green Building Council of Australia Green Star Design &amp; As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B</b></p>	<p align="center"><b>Ardex AF 180MS, One Component Heavy Duty Adhesive</b></p>
<p>General purpose adhesives and sealants: 50 grams per Litre as VOC content per material</p>	<p align="center"><b>&lt;13 grams per Litre as VOC content per material</b></p>
<p align="center"><b><i>We hereby certify Ardex AF 180 MS is well below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></b></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Nick Joy  
BSc (Hons)  
Consultant

CV171205