

VOC Content Test Certificate

Thursday September 15th, 2011

Manufacturer: Ardex Australia (Unit 7, 20 Powers Rd, Seven Hills, NSW 2147)

Sample Description: ARDEX K 005

Date Tested: September 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	ARDEX K 005
One and two pack performance coatings for floors 140 grams per Liter as VOC content material	5.9 grams per Liter as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV110902