

# VOC Content Test Certificate

Thursday December 4<sup>th</sup>, 2008

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road Seven Hills NSW 2147)

Sample Description: Ardex Optima two part premium tile adhesive

Date Tested: December 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>Ardex Optima</b>
Ceramic Tile Adhesive 65 grams per Litre as VOC content material	<b>25 grams per Litre as VOC content per coating</b>
<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>Ardex Optima</b>
Ceramic Tile Adhesive 65 grams per Litre as VOC content material	<b>25 grams per Litre as VOC content per coating</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

F0811-34