

# VOC Content Test Certificate

Thursday, 29<sup>th</sup> December 2022

Supplier: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137, Australia).

Sample Description: RLA Tru Level Bulkfill UT

Date Tested: February 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


|   |  |
|---|--|
| <b>Specification</b><br><br><b>Green Building Council of Australia</b><br><b>Green Star Design &amp; As Built V1.3-13.1.1B</b><br><br><b>Green Star Interiors V1.3-12.1.1B</b>          | <b>RLA Tru Level Bulkfill UT</b>                     |
| <b>General Purpose adhesives and sealants: 50 grams per Litre</b>   | <b>1 grams per Litre as VOC content per material</b> |
| <p><i>We hereby certify that RLA Tru Level Bulkfill UT is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p> |  |



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chem. Eng.)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant

Issue date: 29/12/2022

Expiry date: 28/02/2025

P22120048