

# VOC Content Test Certificate

Thursday, 29<sup>th</sup> December 2022

Supplier: Look Floors (9 Industry Road, Penrose, Auckland, 1061, New Zealand).

Sample Description: STRONGBOND 2000 Universal Resilient Flooring Adhesive

Date Tested: 21 February 2019 (Tested by FORAY Laboratories – NATA Accreditation 1224)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

**Test Data:**

<p align="center"><b>Specification</b></p> <p align="center"><b>Green Building Council of Australia</b></p> <p align="center"><b>Green Star Design &amp; As Built V1.3 13.1.1</b></p> <p align="center"><b>Green Star Interiors V1.3 12.1.1B</b></p>	<p align="center"><b>STRONGBOND 2000</b></p> <p align="center"><b>Universal Resilient</b></p> <p align="center"><b>Flooring Adhesive</b></p>
<p>General purpose adhesives and sealants: 50 grams per Litre as VOC content per material</p>	<p align="center"><b>&lt;1 gram per Litre as VOC content per material</b></p>
<p align="center"><i>We hereby certify STRONGBOND 2000 Universal Resilient Flooring Adhesive is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chem. Eng.)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant

Issue date: 29/12/2022

Expiry date: 21/02/2024

P22120048