

VOC Content Test Certificate

Wednesday, 28th December 2022

Supplier: Look Floors (9 Industry Road, Penrose, Auckland, 1061, New Zealand).

Sample Description: STRONGBOND 888 Carpet Adhesive

Date Tested: February 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3690-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	STRONGBOND 888 Carpet Adhesive
General Purpose adhesives and sealants: 50 grams per Litre	23 grams per Litre as VOC content per material
<p><i>We hereby certify that STRONGBOND 888 Carpet Adhesive is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Luke Morley
BSc (Biotechnology)
Senior Consultant

Issue date: 28/12/2022

Expiry date: 28/02/2025

P22120048