

VOC Content Test Certificate

Thursday, 29th December 2022

Supplier: Look Floors (9 Industry Road, Penrose, Auckland, 1061, New Zealand).

Sample Description: STRONGBOND 970 MS Resilient Adhesive – 10 lt.

Date Tested: January 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


| | |
|--|---|
| <p align="center">Specifications</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B Good Environment Choice Australia</p> | <p align="center">STRONGBOND 970 MS Resilient Adhesive – 10 lt.</p> |
| <p align="center">Wood Flooring and Laminex Adhesives and Sealants Limit: 100 grams per liter</p> | <p align="center">89 grams per Litre as VOC content per material</p> |
| <p align="center">Meets GBCA VOC Content Requirement</p> | <p align="center">Yes</p> |



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
B Sc (Biotechnology)
Senior Consultant

Issue date: 29/12/2022

Expiry date: 29/01/2027

P22120048