

VOC Content Test Certificate

Thursday, 29th December 2022

Supplier: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137, Australia).

Sample Description: RLA Universal Resilient Adhesive

Date Tested: 21 February 2019 (Tested by FORAY Laboratories – NATA Accreditation 1224)


Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Design & As Built V1.3 13.1.1</p> <p>Green Star Interiors V1.3 12.1.1B</p>	<p>RLA Universal Resilient Adhesive</p>
<p>General purpose adhesives and sealants: 50 grams per Litre as VOC content per material</p>	<p><1 gram per Litre as VOC content per material</p>
<p><i>We hereby certify RLA Universal Resilient Adhesive is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue date: 29/12/2022

Expiry date: 21/02/2024

P22120048