

VOC Content Test Certificate

Sunday, 27th July 2025

Supplier: Look Floors (9 Industry Road, Penrose, Auckland 1061, New Zealand).

Product Name: Strongbond 2000 Universal Resilient Flooring Adhesive

Date Tested: 7th July 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Buildings V1 Revision C Exposure to Toxins Credit 13	Strongbond 2000 Universal Resilient Flooring Adhesive
General Purpose Adhesives and Sealants Limit: 50 grams per litre	27 grams per litre as VOC content per material
Meets GBCA VOC Content Requirement	Yes



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant